



# UPPER MACUNGIE TOWNSHIP

## SEWER LATERAL INSPECTION REPORT

This form must be completed by the registered plumber conducting the sewer lateral inspection and submitted in conjunction with a copy of the video. This report will assist the Township in determining whether the sewer lateral is in compliance with the regulation set forth by Upper Macungie Township’s Ordinance #2021-05. If the video does not meet the requirements listed below, the Township may reject the video and request resubmission.

\*\*\*\*FORM MUST BE SUBMITTED TWO WEEKS PRIOR TO SCHEDULED SETTLEMENT\*\*\*\*

**Sewer Lateral Video Requirements:**

- Property address must be included on video
- Display timestamp AND running footage
- Camera must not be completely submerged
- Show lateral from structure to main connection
- Briefly stop at joints to display integrity
- Clearly display cleanout or access point
- Identify where building drain ends, and sewer lateral begins
- USB flash drive accepted in MP4 or WMV format

Property Address:	Date of Inspection:
Plumbing Company Name:	Plumbing Company Address:
Plumber’s Name & License No.:	Plumber’s Phone No. & email:
Property Owner’s Name:	Property Owner’s Phone No.:
Is Property Part of Homeowner’s Association: YES            NO	Property Owner’s Email Address:

**PLEASE INDICATE ANY OF THE FOLLOWING**

Curbside Cleanout:	YES NO	if YES	Connected to the sewer lateral:	YES NO
Building Cleanout:	YES NO	if YES	Connected to the sewer lateral:	YES NO
Sump Pump:	YES NO	if YES	Connected to the sewer lateral:	YES NO
Floor Drains:	YES NO	if YES	Connected to the sewer lateral:	YES NO
Down Spouts:	YES NO	if YES	Connected to the sewer lateral:	YES NO

<b>PIPE MATERIAL:</b>
<b>LOCATION OF CLEAN OUT:</b>
<b>NUMBER OF CLEANOUTS:</b>
<b>VIDEO TO UMT MAIN CONNECTION: YES NO</b>
<b>TOTAL LENGTH:</b>

**PLEASE INDICATED IF ANY OF THE FOLLOWING CONDITIONS APPLY TO THE SEWER LATERAL**

- Cracked or otherwise damaged:  @ \_\_\_\_\_ FOOTAGE  
 Tree Root Infiltration:  @ \_\_\_\_\_ FOOTAGE  
 Other Conditions preventing proper operation:  @ \_\_\_\_\_ FOOTAGE

CUTTING BACK ROOTS IS NOT AN ACCEPTABLE METHOD OF REPAIR

If roots are present, document their location(s) and provide post-cutting video footage. This documentation will allow us to determine whether any inflow or infiltration is occurring at the site and if a repair is required.

ADDITIONAL NOTES:


THE UNDERSIGNED HEREBY AFFIRMS COMPLIANCE WITH UMT MUNICIPAL CODE ORDINANCE 2021-05, AND THAT THE FOREGOING INFORMATION IS TRUE AND CORRECT TO THE BEST OF SAID PERSON'S KNOWLEDGE, INFORMATION, AND BELIEF; SAID AFFIRMATION BEING MADE SUBJECT TO THE PENALTIES PRESCRIBED BY 18 PA C.S. § 4904 (UNSWORN FALSIFICATION TO AUTHORITIES).

Plumber's Signature: \_\_\_\_\_

TOWNSHIP USE ONLY	
RECEIVED BY: _____	DATA SAVED BY/ON: _____ FORWARDED TO PW: Y N
PASS _____	
FAIL _____	PLEASE REFER TO PAGE 3 FOR COMMENTS AND NOTES